

A

1. ALL FLUORESCENT FIXTURES SHALL BE SUPPLIED WITH ENERGY SAVING, HPF ELECTRONIC BALLASTS AND SHALL PROVIDE LESS THAN OR EQUAL TO 10% THD RAPID START.
2. PROVIDE RADIO INTERFERENCE FILTERS (RIF) FOR ALL FLUORESCENT LIGHT FIXTURES.

A